



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण  
(सड़क परिवहन एवं राजमार्ग मंत्रालय, भारत सरकार)  
**National Highways Authority of India**  
(Ministry of Road Transport & Highways, Govt. of India)

गलियारा प्रबन्धन ईकाई CORRIDOR MANAGEMENT UNIT

• 6P, सेक्टर-16A, फरीदाबाद-121002 (हरियाणा) • 6P, Sector-16A, Faridabad-121002 (Haryana)

टेलिफोन : 0129-4004022

Telefax : 0129-4004022

ई-मेल : mat@nhai.org

E-mail : mat@nhai.org

Dated: 24.02.2020

To,  
Team Leader  
URS Scott Wilson India Pvt. Ltd  
JV with Rodic Consultants Pvt. Ltd.  
H. No. 1438, Sec-14, Faridabad-121002

**For the attention of : Sh. K.K. Gupta**

**Sub:** Construction of Additional Structures under Six lining of Delhi - Agra Section of NH-2(New NH-19) in the state of Uttar Pradesh between km 143.000 and 195.100 on EPC mode.

**- Reg. Source Approval for Admixture - Reg.**

Ref: - 1. Contractor letter no -ACPL/DEL-AGRA/URS/2019-121 Dated 31/12/2019  
2. RFI no - CAS/19/063 Dated 20.11.2019

Sir,  
With reference to the above cited letter for review of Admixture for Concrete work as per MORT&H clause 1012.3 and IS 903, 6925, your submitted credentials for the following manufacture is found to be in order.


**1 - Jakco Chemicals**


The acceptance of the Admixture is subject to following conditions:

- Supply of each lot conforms to requirement of IS 9103-1999, 6925.
- Every lot/consignment should accompany the MTC.
- The approval shall be cancelled automatically in case of any negative feedback about performance to specifications.
- The final approval of source will be reviewed by IE after satisfactory results & the source will be approved.

Above is for your kind information and further necessary action please.

Yours Sincerely

  
(Authorized Signatory)  
Delhi-Agra Project.

Receive	
Date :	25/02/2020
Inward No. :	

Cc: Resident Engineer Faridabad & Mathura office for favor of information.

Building a Nation, Not Just Roads / सड़कें ही नहीं राष्ट्र का भी निर्माण

(हम हिन्दी में पत्राचार का स्वागत करते हैं।)

Corporate Office : G - 5 & 6, Sector - 10, Dwarka, New Delhi - 110075

निर्देशित कार्यालय : पी-5 एवं 6, सेक्टर-10, द्वारका, नई दिल्ली-110075



**OFFICE OF THE EXECUTIVE ENGINEER**  
**P.W.D. NATIONAL HIGHWAY DIVISION GWALIOR**



Email: ccpwdnhgwl@gmail.com

☎ 0751-2495525, 2452446

Letter No. 2012 /Technical/NH/2024

Gwalior Dated- 29/08/2024


To, ✓  
Authority of YFC-KCC (JV)  
YFC House, at plot-14, BLOCK-B  
Infocity Sector-34, Gurgram 122001  
Haryana India+

Subject:-Construction of Morena, Ambah & Porsa Bypass Length 27.16 Km Section NH -552  
Existing Two Lane with Paved Shoulder Configuration in the state of Madhya Pradesh  
on EPC Mode

Ref- Agreement 115/CE/NH2024-25 Date - 28-06-2024 & job number.....

- (i) Your Letter No. 0017 Date- 26-07-24 For Cement Credential
- (ii) Your Letter No.0020 Date - 06-08-2024 for Chemical Admixture
- (iii) Your Letter No.0021 Date - 07-08-2024 for Credentials for reinforcement
- (iv) Your Letter No.0015 Date- 22-07-2024 for Quality Assurance plan


With reference to above subject cited to your above letter details utilized in cited of  
project work the following several reputable brands are approved

  
Executive Engineer  
P.W.D. N.H. Division Gwalior  
Gwalior Dated-

Endo No. /Technical/NH/2024

Copy Forwarded to :-

Chief Engineer National Highway PWD NH Zone Bhopal Bhopal for information

  
Executive Engineer  
P.W.D. N.H. Division Gwalior

Date: 06.08.2024

Lt. No. YFC-KCC (JV)/MP/24-25/0020

To,  
The Executive Engineer,  
PWD, NH Division Gwalior  
Madhya Pradesh,  
Email: cepwdnhgw1@gmail.com

**Project:** - "Construction of Morena Bypass, Ambah Bypass, Porsa Bypass (Total Length 27.16 Km) Section of NH-552 Ext. to two lane with Paved Shoulder Configuration in the state of Madhya Pradesh on EPC Mode".

**Subject:** - Submission of Chemical Admixture Profiles for approval.

**Ref:** - Contract Agreement No. 115/CE/NH/2024-25 dated 28.06.2024.

Dear Sir,

I hope this message finds you well.



We are pleased to present the profiles of various Chemical Admixture for your approval, following are our proposal:

1. Jacko chemicals
2. Metro chemicals

We kindly request you to approve these profile as early as possible. The copies of both profiles are attached with this letter for your reference.


Thank you for your attention to this matter.

For YFC-KCC (JV)

Authorized Signatory





"YFC House", at Plot -14, Block -B, Infocity, Sector-34, Gurugram 122001,  
Haryana, India

Email Id: yfc@yfc.com



LEA Associates South Asia Pvt. Ltd.

In Association with

Pioneer Infra Consultants Pvt. Ltd.

House No. 456, Sector-9, Urban Estate,

Ambala City, Ambala (Haryana) 134003

Email: lasaambala@lasaindia.com, www.lea.ca

Corporate Identification Number: U74899DL1993PTC055750

LASA/MCL/Shamli-Ambala/73874/AE/2024/2442

Date: 16-08-2024

To

**The Authorized Signatory**

Montecarlo Limited

Shamli- Ambala Project Pkg-3

Village & Post-Bihta, Dist. -Ambala

Haryana-133101, India.

**Subject:-**Consultancy Service for Authority's Engineer for supervision of Development of six lane access control highway of Bareilly-Ludhiana economic corridor under Bharatmala Pariyojana from RanipurBarsi Saharanpur district to Sadopur Ambala District Ch. 84+400 to 121+786 of Shamli Ambala section in the state of Haryana on EPC Mode (Package-III)- **Reg:- Submission of the Credentials of M/s Jakco Chemicals for Source Approval of Admixture.**

**Ref:-**MCL (P) HW/1230/CON/2024-2025/ 341 dated: 09-08-2024.

Dear Sir,

This has reference to your letter cited above, we have reviewed the credentials of M/s Jakco Chemicals. In respect of procurement of Chemical admixture to be used for concrete work, which has been found in order. Therefore, the source is accepted for construction purpose at site.

Further, procured material should be tested frequently for the confirmation of compliances with the specifications and for the stock approval, sample collection shall be done jointly with Authority Engineers representative and the EPC contractor should ensure that the test is conducted in a fair and efficient manner and routine third party testing of the samples shall be carried out from the approved NABL accredited laboratory and test report to be submitted to this office for our review.

This confirmation is subject to the following conditions:

1) Every batch/lot of supply shall be provided

Invoice copy and with the manufacturer test certificate comply with IS/ MoRT&H specification.

2) Third party testing of all physical and chemical test of each lot of the admixture shall be done in the NABL accredited laboratory approved by us.

3) Mix design of concrete using the admixture along with its trade name needs to be submitted.

4) Only fresh material shall be procured.

Thanking you

Yours sincerely,

**For LEA Associates South Asia Pvt. Ltd.**

(Lakshmi Narayan)


Team Leader

(LASA Ambala Site Office)

Copy to :1. Project Director NHAI PIU-Ambala for information.

2. Mr. A K Sharma, CGM Cum Project Coordinator & Mr. Suddhashil Purkait, LASA New Delhi

3. RE-II /SOME/BE - to perceive.



**HARYANA PWD B&R BRANCH**

Executive Engineer,  
Provincial Division,  
PWD B&R Br., Faridabad  
Tel No. 0129-2288187 (O) E-mail -  
pood.acpt1.faridabad@hry.pw.in

To

M/s KCC Sheeraj Projects Pvt. Ltd. (DVL)  
5<sup>th</sup> Floor, JMD Empire,  
Golf Course Extension Road,  
Sector -62, Gurugram-122102

Memo No. 4545 /DB

Dated: 09/07/24

Subject:

Construction of elevated road with service road from Delhi- Agra road (NH-19) to DND- Faridabad- Ballabgarh bypass KMP link (Spur to Delhi- Mumbai Expressway) via Ballabgarh- Mohna road in Faridabad District in the State of Haryana- Regarding submission of Company credential of Admixture.

Reference:

Your office letter No. KCC-SHEERAJ(JV)HR-PWD/DF8/2024-25/003 dated 11.06.2024

As proposed vide letter under reference and recommended by Sub Divisional Engineer, Provincial Sub Division, PWD B&R Branch, Ballabgarh vide letter No. 538 dated 03.07.2024 and after examine the documents attached with proposal for construction of elevated road with service road from Delhi- Agra road (NH-19) to DND- Faridabad- Ballabgarh bypass KMP link (Spur to Delhi- Mumbai Expressway) via Ballabgarh- Mohna road in Faridabad District. Following four number agencies are hereby approved for providing admixture. The detail of agencies are given as under :-

1. Yahska Polymers Pvt. Ltd., Survey No. 7, Khata No. 1217, 8/h Sarvodaya Hotel, Opposite Param Cylinder Village Moraiya, Changodar, Ahmedabad- 382213 (Gujrat)
2. Metro Chemicals, Khasra No. 595/599, Mitrol Deeghot Road Palwal- 121105
3. Jakco Chemical, Plot No. 18 Sector -2A, Vaishali Ghaziabad- 201010 (UP)
4. M/s Rheoplat Technology Pvt. Ltd., Survey No. 30/2, At-Pilosaru Post Pali, Sudhagad District Raigad- 410205 Maharashtra.

DA/Nil

Executive Engineer,  
Provincial Division,  
PWD B&R Br., Faridabad

Endst.No.

4546

/DB Dated:

09/07/24

Copy of above is forwarded to the Superintending Engineer, Gurugram Circle, PWD B&R Branch, Gurugram for information please.

DA/Nil

Executive Engineer,  
Provincial Division,  
PWD B&R Br., Faridabad

Endst.No.

4547

/DB Dated:


09/07/24

Copy of above is forwarded to the Sub Divisional Engineer, Provincial Sub Division, PWD B&R Branch, Ballabgarh for information. This is w.r.t. his letter No. 538 dated 03.07.2024.

DA/Nil

Executive Engineer,  
Provincial Division,  
PWD B&R Br., Faridabad

DMDM



LNM-HSR/STRR/P-3/2022-23/367

Date: 05-03-2024

To,  
The Authorized Signatory,  
M/s Montecarlo Balagondapalli Highway Pvt. Ltd.,  
Survey No. 458/1, Village: Thorapalli Agraham,  
Thorapalli Panchayat, PO: Onnalvadi, Tq: Hosur,  
District: Krishnagari, Tamil Nadu – 635109.  
Email: balagondapalli.str@mclindia.com

Sub: "Consultancy Services for Independent Engineer for Supervision of construction of STRR (West side)-NH948A-Balagondapalli (Tamil Nadu) to Karnataka/Tamil Nadu Border from Km 144.170 to Km 179.936 (35.766 Km) in the State of Tamil Nadu on Hybrid Annuity Mode under Bharatmala Pariyojana": - **Submission of Credentials & Company Profile for Concrete Admixture(JAK-PC70), Curing Compound (JAK CURES - Wax Based & JAK CURES – Resin Based) & Polysulphide Sealant (JAK Seal) of Source M/s Jakco Chemicals for Source Approval. – reg.**

Reference: 1. Concession Agreement dated 24.05.2022.

2. Your letter no. MCL(P)/HW/2230/CON/2023-2024/533 dated 26.02.2024 received on 28.02.2024.

Sir,

This has reference to vide your letter cited at 2 above wherein you have submitted the credentials and company profile of M/s **Jakco Chemicals** for Source clearance of Chemical Admixture, Curing Compound (JAK CURES=Wax Based & JAK CURES – Resin Based) & Polysulphide Sealant (JAK Seal) to use in Concrete works for the subject project.

We have reviewed the above submitted credentials and company profile of M/s Jakco Chemicals and found generally in order. Thus, we hereby grant provisional approval to procure the same in the subject project subjected to fulfilment of the following conditions:

- 1) The submitted copy of valid BIS (Bureau of Indian Standards) Certificate / License issued to M/s Jakco Chemicals for manufacturing of Water reducing Admixture was expired on 12.07.2023. Thus, renewal copy shall be furnished for our review. It is advised not to proceed ahead with procurement and utilize in the permanent works unless furnish the valid BIS Certificate to IE review and approval.
- 2) The copy of valid BIS (Bureau of Indian Standards) Certificate / License issued to M/s Jakco Chemicals for manufacturing of Curing compound and Polysulphide Sealant have not been furnished. Hence, the same shall be furnished to our review.
- 3) Trail mixes shall be conducted in the presence of Representative's of Independent Engineer and shall be confirmed by product by using the above source of admixture for structural concrete and Pavement Quality Concrete (PQC) works, prior to use in permanent works.
- 4) The Chemical admixture and curing compound shall meet all the requisite Standards and Specifications of MoRTH / IS:9103 and BS-7542 respectively.

Plot No.1, M.P. Register Office: Plot No. 29, F/F Sector-II, Dwarka, New Delhi – 110078

Corporate Office: T-10, 11th Floor, City Centre, Press Complex,

Plot No.1, M.P. Nagar, Zone-I, Bhopal (M.P.) 462011.

Tel./Fax: 0755 – 4295421. e-mail: lnmalviya@lninfra.com Web.: www.lninfra.com

- 5) The Polysulphide sealant shall conform to IS:12118, BS:4254, BS:5212 part-2.
- 6) Each consignment of admixture, curing compound and Polysulphide sealant should accompany the Manufacturer's Test Certificate.
- 7) Compatibility of admixture with the cement being used shall be tested before actual use in the works. The test shall be repeated in case of change of type or grade or source of cement.
- 8) The first consignment and subsequently at reasonable intervals shall be tested for physical and chemical properties from the approved NABL independent laboratory at the expense of Concessionaire and test reports shall be submitted to IE review and record.
- 9) The admixture shall not impair the durability of concrete. It shall not combine with the ingredients to form harmful compounds or endanger the protection of reinforcement against corrosion.
- 10) The packaging of admixture shall clearly indicate the name of the manufacturer/supplier, brand name (name of the product), date of production and expiry, batch/identification number.
- 11) If any lot/consignment is found to be defective, the same shall be removed immediately from site and subsequently approval will be withdrawn without any prior notice.

Final approval will be accorded after satisfactory/fulfilment of the above.

Thanking you.

Yours sincerely,

For L N Malviya Infra Projects Pvt. Ltd.

In Association with M/s Intratech Civil Solution & Consultant.

  
(V. JYOTHEESWARA REDDY)

**Team Leader**

Copy to: 1) The Project Director, NHAI, PIU, Bengaluru (Expressway) – for kind information.



राइट्स लिमिटेड  
(भारत सरकार का प्रतिष्ठान)  
**RITES LIMITED**  
(Schedule 'A' Enterprise of Govt. of India)

NO: RITES/NRPO/CONCOR /ICD-Dadri/Parking/Test/Site/2024/08

Date: 25.01.2024

To,  
M/s GHAZIABAD Testing Laboratory Pvt. Ltd.  
AO-150, Amit Steel Compound,  
South Side, GT Road, Industrial Area  
Ghaziabad - 201001 (U.P.)  
Mobile No.0120-2866108  
Email- [enquiry@gtlab.org](mailto:enquiry@gtlab.org)

**(Kind Attention: Mr. Dheeraj Verma)**

**Sub:** Construction of Pavement in Truck Parking Area at ICD Dadri.

**Ref:** LOA No.CON/EP/Dadri/Area-1/Pavement/Dadri/2023-24/E-65922/4629 dated 27/11/2023.

**Regarding:** Design Mix for Reinforced Cement Concrete (M-25)

Dear Sir,

Please find herewith the following sealed samples of materials for conducting design mix of RCC for grade M-25 with minimum cement content 330 kg/cum with Birla Uttam Cement OPC 43,W-2.

SI No.	Description	Source
1	Birla Uttam OPC-43,W-2 ( 1 Bag)	Mangalam Cement Limited,Kota, Rajasthan
2	Stone aggregate 20 mm( 2 Bags)	Pali,Rajasthan
3	Stone aggregate 10 mm( 2 Bags)	Pali,Rajasthan
4	Fine aggregate/coarse sand ( 2 Bags)	Bajpur,Uttarakhand
5	Admixture Pc 100 ( 2 litre)	M/s JAKCO Chemicals (P) ,Ghaziabad,U.P
6	Water ( 25 litre)	From Borewell b/w WH1 & WH2 at CONCOR

Minimum basic requirement for design mix area as follows-

- 1) Slump not more than 80-100 mm with admixtures
- 2) Retention time for checking of workability- 60 min
- 3) Exposure condition – Moderate

You are requested to evaluate all physical and chemical parameters of all materials and design the concrete mix.

*Received by Mr. Dheeraj Verma*

Transforming to GREEN

कॉर्पोरेट कार्यालय: शिखर, प्लॉट नं. 1, सेक्टर-29, गुरुग्राम-122 001 (भारत). Corporate Office: Shikhar, Plot No.1, Sector-29, Gurugram-122 001  
पंजीकृत कार्यालय: स्कोप मीनार, लक्ष्मी नगर, दिल्ली-110 092 (भारत). Registered Office: SCOPE Minar, Laxmi Nagar, Delhi- 110 092 (India)  
दूरभाष (Tel.): (0124) 2571666. फैक्स (Fax): (0124) 2571660. ई.मेल (E-mail) [info@rites.com](mailto:info@rites.com) वेबसाइट (Website): [www.rites.com](http://www.rites.com)

CIN: L74899DL1974GOI007227

8362

"हर बूढ़ संचय, हर खेत पानी"



Superintending Engineer  
Y.W.S. Circle, Karnal  
Irrigation & W.R. Deptt. Haryana

No. 3381/70-W

Dated 21/04/2022

To

NO. 880  
Case 1-S  
Date 21/4/2022  
Dy. Supdt./DAO/DSD/HRK

The Executive Engineer,  
Karnal W.S. Division,  
Karnal

*[Handwritten signature]*

**Sub:- Approval of Design Mix M-10, M-15 & M-25 for the work "Remodelling of Augmentation Canal".**

**Ref:-** Your office letter No. 449/1-S dated 05.04.2022.

As recommended vide your office letter under reference on the above cited subject, the Test Report of Design Mix Concrete M-10, M-15 and M-25 for the work of Remodelling of Augmentation Canal is hereby approved in accordance with the instructions issued by the Engineer-In-Chief Irrigation & W/R Deptt. Haryana, Panchkula vide letter No. 617-54/XEN-Work/2019 dated 01.04.2019 with the following conditions:-

1. Approval of Test Report of Design Mix Concrete by Superintending Engineer, YWS Circle, Karnal will not absolve the Consultant/ Assistant Professor. Sh. HD Chalak, Civil engineering Deptt., National Institute of Technology, Kurukshetra from his responsibility regarding correctness of Test Report of Design Mix Concrete.
2. If source of material is changed, then Design Mix should be got designed afresh and till receipt of Design Mix test report, work should not be executed at site with substituted material.
3. The copy of Approved test report of Design Mix Concrete be sent to XEN/Vigilance Division Karnal.
4. All the construction material such as cement, coarse aggregate and fine aggregate + Admixture to be used in Design Mix Concrete should confirm to IS Standards.
5. Fresh cement should be used for each and every Design Mix Concrete.

588  
204  
25/4/22

Sh. Anurag Kumar JE  
Sh. Vijay Kumar JE  
Approved Design Mix Conc.  
M-10, M-15 & M-25

*[Handwritten signature]*  
Superintending Engineer,  
YWS Circle, Karnal  
25/4/2022

No. 3478-80 / 1-S  
copy of above is forwarded to SDO Nalk, SDO/Asst and XEN/Vigilance Karnal for information and action

*[Handwritten signature]*

Consultancy

**H.D.Chalak**  
Ph.D.(Structures)  
Assistant Professor  
Civil Engineering Department  
National Institute of Technology  
Kurukshetra-136119



Resi. Address:- CC-05, NIT  
Kurukshetra,  
Kurukshetra-136118.  
01744-233340 (O)  
01744-238050 (Fax)  
07206514129 (M)  
chalakhd@nitkkr.ac.in

RC/C/HDC/2021/108/1745

Job No. HDC/21-22/108(02)  
Date:31.03.2022

To,  
The Sub Divisional Officer  
Assandh W/S Sub Division,  
Assandh.

Sub:- Test report of Concrete Mix Design of M10, M15 and M25 for the work of  
augmentation of canal  
Ref.: Letter No. 88-90/Aug dated 21.02.2022

Sir,  
With reference to your letter No. 88-90/Aug dated 21.02.2022 in this regard. The details of  
materials received are as:

Sr.No.	Material	Source
1	Cement	Shree Cement OPC 43
2	Aggregate 20 mm	
3	Aggregate 10 mm	
4	Stone Dust/ Sand/ M-Sand	
5	Admixture	Jakplast-905/PE-0110

Find enclosed herewith the test report of Concrete Mix Design of M10, M15 and  
M25, for the work. This is for your information.

D.A.: Test Reports.

Recommended

Dr. H. D. CHALAK  
Assistant Professor  
Department of Civil Engineering  
National Institute of Technology  
Kurukshetra-136119

Executive Engineer  
Karnal W/S Division  
Irr. & W.R. Department  
(Haryana) Karnal

Sub Divisional Officer

PP RAVED

Page: 108(02)-1/5



**CHAITANYA**

PROJECTS CONSULTANCY (P) LTD.  
(An ISO 9001:2015 Certified Company)

CORPORATE OFFICE:  
101, 1st Floor, Tower No. 3, Okaya Centre,  
Block-B, Sector-62, Noida - 201301, India  
Tel. 0120-4120472 | 41120472  
Email: aeho.dsd\_baghpat@cpcmail.in

in JV with



**ISAN CORPORATION**

PROJECT SITE OFFICE:

H/o Rahul Kumar S/o Ajab Singh,  
Ward No. 4, Near Bank of Baroda and UCO Bank  
Meerut Road, Baghpat, Uttar Pradesh - 250609.  
Email: aefl.dsd\_baghpat@cpcmail.in

**Letter No. CPCPL/DDE/PKG-2/13**

**Date: 06-05-2022**

To,  
The Project Manager  
Krishna Constellation Pvt.Ltd.  
Delhi Saharanpur Greenfield Project,  
B-901, 9<sup>th</sup> Floor, Golden Heights, Green Wood City, Meerut-250002 (U.P.)

**Sub:** Development of six lane access control Greenfield highway of Delhi-Saharanpur – Dehradun economic corridor under Bharatmala Pariyojana from Design Chainage 27+000 (Vill – Lohadda) to Design Chainage 56+500 (Karaund Mahajan) in the state of Uttar Pradesh (Package-II) On epc mode: **Reg- Source approval for Admixture from M/s Jakco Chemicals.**

**Ref: KCC/DDE/PKG-2/2022-2023/008 Date-22/04/2022**

Dear Sir,

With reference to your letter no **KCC/DDE/PKG-2/2022-2023/020 Date-05/05/2022** Regarding Third Party Test Report forwarded in case of M/s Jakco Chemicals (JAKPLAST-907) the source approval of admixture from firm is approved accordingly.

Thanking You

For chaitanya project consultancy pvt.ltd,  
Isan Corporation

(Kuldeep Kumar Razdan)

Team Leader cum Sr.Highway Engineer

**Copy to:** 1. Project Director PIU Baghpat. For your information and record please.  
2. CPCPL Head office. (aeho mail)





**SA INFRASTRUCTURE**  
CONSULTANTS PVT LTD

Corporate  
1101A, 11th Floor, Tower A-II, Corporate  
Plot No. 7A/1, Sector 142, Noida 201301, Uttar Pradesh  
Tel: +91-120-6148000 | Tel./Fax: +91-120-6148001  
Email: info@sainfra.com  
CIN NO. U74140DL2005PTC  
MSME Reg. No. UP28F0

This is for your kind information and necessary compliance please.

Thanking You,

Yours Sincerely,  


**(Anjani Kumar Sinha)**  
**Team Leader Cum Senior Highway Engineer**  
**For, SA Infrastructure Consultants Pvt Ltd.**  
**In Joint Venture with**  
**Technocrats Advisory Services Pvt. Ltd.**  
**In association with**  
**Upham International Corporation**

**Copy to:** 1. Project Director, PIU- Munger  
2. HO SAICPL, Noida

- for your kind information.  
- for your kind information.